

TECHNICON DESIGN GROUP, INC.  
 1800 N. PERRY STREET - SUITE 102  
 OTTAWA, OHIO 45875  
 PHONE: 419.523.5323  
 FAX: 419.523.9441

DATE: July 17, 2017  
 PROJECT NAME: Henry County Commissioners  
 Proposed Alterations  
 PROJECT NUMBER: 51-2246-16

**INTENT:**

This Addendum provides modifications and clarifications To the Bid Documents dated 06/22/17. Bidder shall ascertain prior to submitting its Bid Form that it has received all Addenda issued and shall acknowledge receipt of each Addendum on the Bid Form.

In the event of a conflict between the terms and provisions of this Addendum and the terms and provisions of the Bidding Documents, the terms and provisions of this Addendum shall control. In all other respects, the Bidding Documents shall remain unchanged and in full force and effect.

ITEM	ADD DRAWING	CD REFERENCE	DESCRIPTION
<b>ARCHITECTURAL:</b>			
1		Sheet A101	Add one additional fire extinguisher (Key Note #40) to be surface mounted on existing column.
2		Sheet A201	Revise note for Enlarged Floor Plan 1/A201 to read: G.C. shall patch any and all holes in Rooms 102, 103 & 114 existing gyp. bd. - finish and prime and paint all gyp. bd. surfaces. <b>Plumbing walls and north walls of Rooms 102 and 103 shall be painted with epoxy paint</b> - color as selected by owner
<b>ELECTRICAL:</b>			
3		E100	Replace existing outlets with GFCI outlets in 14 locations about perimeter of building.
<b>MECHANICAL:</b>			
<b>PLUMBING:</b>			

END OF ADDENDUM 02