



Date: 10/15/2025

Project Number: 76-2829-22

Project Name: Henry Count Courthouse - Interior Renovations

Intent:

This Addendum provides modifications and clarifications To the Bid Documents dated **Tuesday, September 23, 2025**, Bidder shall ascertain prior to submitting its Bid Form that it has received all Addenda issued and shall acknowledge receipt of each Addendum on the Bid Form.

In the event of a conflict between the terms and provisions of this Addendum and the terms and provisions of the Bidding Documents, the terms and provisions of this Addendum shall control. In all other respects, the Bidding Documents shall remain unchanged and in full force and effect.

Item	Additional Document	Cons. Doc. Reference	Description
Plumbing:			
1		CLARIFICATION	CLARIFICATION: Copper press fittings are acceptable on above grade heating water piping.
End of Addendum 02			